



Underwriters Laboratories Inc.®

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 051102 - E181875

ISSUE DATE: 11-05-2002

Page 1 of 2

Issued to: Excelsys Technologies Ltd
Swords Business Park
CO Dublin Ireland

Report Reference: E181875, June 21, 2000



This is to Certify that representative samples of: Switching Power Supply Model 3, Gen. Type 3G4X-YYYY-WZZZP, 4-Slot
X = B for 400 W input model or C for 600 W input model.
Y = Any number from 0 through to 7.
W = -, K or X
Z = Any number from 000 to 509, representing option code.
P = Any alphanumeric character

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1950_3 - Safety of Information Technology Equipment
CSA C22.2 No. 950-95 - Safety of Information Technology Equipment

Additional Information: See Addendum for Electrical Ratings

Only those products bearing the UL Recognized Component Markings for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Marking for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark  may be used in conjunction with the required Recognized Markings. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Marking for Canada consists of the UL Recognized Mark for Canada:  and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory

LOOK FOR THE UL RECOGNIZED COMPONENT MARKING ON THE PRODUCT

Engineer:

C. Sivour-Toft - Associate Project Engineer
UL International (UK) Ltd.

Review Engineer:

D. Snook - Project Engineer
UL International (UK) Ltd.

Pursuant to the Corporate Services Agreement between UL International (UK) Ltd. and Underwriters Laboratories Inc. ("UL"), UL hereby accepts and issues this Certificate of Compliance. For questions in United Kingdom, you may call +44 0 1483 302130.

 **Underwriters Laboratories Inc.®**
CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 051102 - E181875

Page 2 of 2

ISSUE DATE: 11-05-2002

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UR and cUR requirements.

ELECTRICAL RATING:


Voltage: 100-253 V
Frequency: 47-63 Hz
Current: 10 A

<u>Output Module</u>	<u>Voltage (V dc)</u>	<u>Current (A)</u>	<u>Max Power (W)</u>
1	5	30	150
2	12	20	240
3	18	15	270
4	24	12	288
5	24	3	72
	24	3	72
6	5	10	50
	24	3	72
#70#	5	80	400

Module 70 occupies two slots.
Total power not to exceed 600 W.

Engineer:

C. Sivyoun Toft - Associate Project Engineer

Review Engineer:

D. Snook - Project Engineer

Pursuant to the Corporate Services Agreement between UL International (UK) Ltd. and Underwriters Laboratories Inc. ("UL"), UL hereby accepts and issues this Certificate of Compliance.